



26 0536 –
Cable Trays for Electrical Systems

Page 1 of 1

Last Update: [May 12, 2017](#)

A. Materials & Construction:

1. Cable tray shall be ladder type and installed only within MDF and IDF rooms per standard BSU details.
2. Do not use cable tray in corridors or spaces other than MDF and IDF rooms.

B. Support:

1. Cable trays shall be supported from building structure using hangers manufactured by tray manufacturer and sized for the tray being installed and per manufacturers' written recommendations
2. Install approximately 6" above the top of the equipment racks in configuration shown on BSU standard details.

C. Approved Manufacturers:

1. Chatsworth Universal Cable Runway 10250 Series, 12" wide.