



**26 5300 –
Exit Signs**

Page 1 of 1

Last Update: [May 12, 2017](#)

- A. Housing – Sturdy construction (commercial grade) requiring only simple hand tools to open the housing for maintenance.
- B. Finishes – Brushed aluminum, white or black with matching end and ceiling mounts.
- C. Lamps – LED
- D. Lettering color – Green unless existing signs in building are another color. Then, match to existing color in building.
- E. Exit sign shall be available as single or double faced unit with universal “snap-out” directional arrows.
- F. Self -Diagnostic – Prefer battery backed exits to be the non-self diagnostic type. Only use battery packs when a standby generator source is not available.
- G. Exits shall be powered from the emergency generator where available.
- H. Universal voltage.