



**26 5600–**  
**Exterior Lighting**

Page 1 of 1

Last Update: May 12, 2017

1. Exterior lighting fixtures on the BSU campus are predominantly High Pressure Sodium lamped however BSU has begun to use LED fixtures in select areas. Coordinate with BSU Engineering prior to specifying ANY exterior lighting fixtures. This includes all entrance, area, parking lot, roadway, landscape and sign lighting.
2. Control. Prefer all exterior lighting be controlled with a contactor or contactors using a simple photocell for the contactor coil circuit. Mechanically held contactors shall be used. Do not use the building management system, timeclocks or specialty lighting control systems.